

August 18, 2017

Mr. Rafael Torres
PARS Environmental
500 Horizon Drive
Trenton, NJ 08691

Certificate of Analysis

Project Name:	School Drinking Water Lead Testing	Workorder:	2254151
Purchase Order:		Workorder ID:	Clinton Twp BOE-CTM (1211-01)

Dear Mr. Torres:

Enclosed are the analytical results for samples received by the laboratory on Monday, August 14, 2017.

The ALS Environmental laboratory in Middletown, Pennsylvania is a National Environmental Laboratory Accreditation Program (NELAP) accredited laboratory and as such, certifies that all applicable test results meet the requirements of NELAP.

If you have any questions regarding this certificate of analysis, please contact Mrs. Vicki A. Forney (Project Coordinator) at (717) 944-5541.

Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state requirements. The test results meet requirements of the current NELAP standards or state requirements, where applicable. For a specific list of accredited analytes, refer to the certifications section of the ALS website at www.alsglobal.com/en/Our-Services/Life-Sciences/Environmental/Downloads.

This laboratory report may not be reproduced, except in full, without the written approval of ALS Environmental.

ALS Spring City: 10 Riverside Drive, Spring City, PA 19475 610-948-4903

This page is included as part of the Analytical Report and must be retained as a permanent record thereof.



Mrs. Vicki A. Forney
Project Coordinator

ALS Environmental Laboratory Locations Across North America

Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay
Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

SAMPLE SUMMARY

Workorder: 2254151 Clinton Twp BOE-CTM (1211-01)

Lab ID	Sample ID	Matrix	Date Collected	Date Received	Collected By
2254151001	CTM-FIELD BLANK	Drinking Water		8/14/2017 18:45	Collected by Client
2254151002	CTM-1-KIT-FP2-P	Drinking Water		8/14/2017 18:45	Collected by Client
2254151003	CTM-1-KIT-FP2-F	Drinking Water		8/14/2017 18:45	Collected by Client
2254151004	CTM-1-KIT-FP4-P	Drinking Water		8/14/2017 18:45	Collected by Client
2254151005	CTM-1-KIT-FP4-F	Drinking Water		8/14/2017 18:45	Collected by Client
2254151006	CTM-1-163A-EC3-P	Drinking Water		8/14/2017 18:45	Collected by Client
2254151007	CTM-1-163A-EC3-F	Drinking Water		8/14/2017 18:45	Collected by Client
2254151008	CTM-1-163A-EC6-P	Drinking Water		8/14/2017 18:45	Collected by Client
2254151009	CTM-1-163A-EC6-F	Drinking Water		8/14/2017 18:45	Collected by Client
2254151010	CTM-1-163A-EC7-P	Drinking Water		8/14/2017 18:45	Collected by Client
2254151011	CTM-1-163A-EC7-F	Drinking Water		8/14/2017 18:45	Collected by Client

ALS Environmental Laboratory Locations Across North America

Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay
Vancouver Waterloo · Winnipeg · Yellowknife **United States:** Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York **Mexico:** Monterrey

SAMPLE SUMMARY

Workorder: 2254151 Clinton Twp BOE-CTM (1211-01)

Notes

- Samples collected by ALS personnel are done so in accordance with the procedures set forth in the ALS Field Sampling Plan (20 - Field Services Sampling Plan).
- All Waste Water analyses comply with methodology requirements of 40 CFR Part 136.
- All Drinking Water analyses comply with methodology requirements of 40 CFR Part 141.
- Unless otherwise noted, all quantitative results for soils are reported on a dry weight basis.
- The Chain of Custody document is included as part of this report.
- All Library Search analytes should be regarded as tentative identifications based on the presumptive evidence of the mass spectra. Concentrations reported are estimated values.
- Parameters identified as "analyze immediately" require analysis within 15 minutes of collection. Any "analyze immediately" parameters not listed under the header "Field Parameters" are performed in the laboratory and are therefore analyzed out of hold time.
- Method references listed on this report beginning with the prefix "S" followed by a method number (such as S2310B-97) refer to methods from "Standard Methods for the Examination of Water and Wastewater".
- For microbiological analyses, the "Prepared" value is the date/time into the incubator and the "Analyzed" value is the date/time out the incubator.

Standard Acronyms/Flags

J	Indicates an estimated value between the Method Detection Limit (MDL) and the Practical Quantitation Limit (PQL) for the analyte
U	Indicates that the analyte was Not Detected (ND)
N	Indicates presumptive evidence of the presence of a compound
MDL	Method Detection Limit
PQL	Practical Quantitation Limit
RDL	Reporting Detection Limit
ND	Not Detected - indicates that the analyte was Not Detected at the RDL
Cntr	Analysis was performed using this container
RegLmt	Regulatory Limit
LCS	Laboratory Control Sample
MS	Matrix Spike
MSD	Matrix Spike Duplicate
DUP	Sample Duplicate
%Rec	Percent Recovery
RPD	Relative Percent Difference
LOD	DoD Limit of Detection
LOQ	DoD Limit of Quantitation
DL	DoD Detection Limit
I	Indicates reported value is greater than or equal to the Method Detection Limit (MDL) but less than the Report Detection Limit (RDL)
(S)	Surrogate Compound
NC	Not Calculated
*	Result outside of QC limits

ALS Environmental Laboratory Locations Across North America

Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay
Vancouver Waterloo · Winnipeg · Yellowknife **United States:** Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York **Mexico:** Monterrey

ANALYTICAL RESULTS

Workorder: 2254151 Clinton Twp BOE-CTM (1211-01)

Lab ID: **2254151001** Date Collected: Matrix: Drinking Water
 Sample ID: **CTM-FIELD BLANK** Date Received: 8/14/2017 18:45

Parameters	Results	Flag	Units	RDL	Method	Prepared By	Analyzed By	Cntr
METALS								
Lead, Total	ND		ug/L	2.0	EPA 200.8	8/17/17 17:45 MO	8/17/17 21:44 MO	A1

Vicki Forney
 Mrs. Vicki A. Forney
 Project Coordinator

ALS Environmental Laboratory Locations Across North America


Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay
 Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

ANALYTICAL RESULTS

Workorder: 2254151 Clinton Twp BOE-CTM (1211-01)

Lab ID: **2254151002** Date Collected: Matrix: Drinking Water
 Sample ID: **CTM-1-KIT-FP2-P** Date Received: 8/14/2017 18:45

Parameters	Results	Flag	Units	RDL	Method	Prepared By	Analyzed By	Cntr
METALS								
Lead, Total	27.3		ug/L	2.0	EPA 200.8	8/17/17 17:45 MO	8/17/17 21:47 MO	A1



Mrs. Vicki A. Forney
 Project Coordinator

ALS Environmental Laboratory Locations Across North America

Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay
 Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

ANALYTICAL RESULTS

Workorder: 2254151 Clinton Twp BOE-CTM (1211-01)

Lab ID: **2254151003** Date Collected: Matrix: Drinking Water
 Sample ID: **CTM-1-KIT-FP2-F** Date Received: 8/14/2017 18:45

Parameters	Results	Flag	Units	RDL	Method	Prepared	By	Analyzed	By	Cntr
METALS										
Lead, Total	2.9		ug/L	2.0	EPA 200.8	8/17/17 17:45	MO	8/17/17 21:49	MO	A1

Vicki Forney
 Mrs. Vicki A. Forney
 Project Coordinator

ALS Environmental Laboratory Locations Across North America

Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay
 Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

ANALYTICAL RESULTS

Workorder: 2254151 Clinton Twp BOE-CTM (1211-01)

Lab ID: **2254151004** Date Collected: Matrix: Drinking Water
 Sample ID: **CTM-1-KIT-FP4-P** Date Received: 8/14/2017 18:45

Parameters	Results	Flag	Units	RDL	Method	Prepared By	Analyzed By	Cntr
METALS								
Lead, Total	9.1		ug/L	2.0	EPA 200.8	8/17/17 17:45 MO	8/17/17 21:52 MO	A1

Vicki Forney
 Mrs. Vicki A. Forney
 Project Coordinator

ALS Environmental Laboratory Locations Across North America


Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay
 Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

ANALYTICAL RESULTS

Workorder: 2254151 Clinton Twp BOE-CTM (1211-01)

Lab ID: **2254151005** Date Collected: Matrix: Drinking Water
 Sample ID: **CTM-1-KIT-FP4-F** Date Received: 8/14/2017 18:45

Parameters	Results	Flag	Units	RDL	Method	Prepared By	Analyzed By	Cntr
METALS								
Lead, Total	2.7		ug/L	2.0	EPA 200.8	8/17/17 17:47 MO	8/17/17 22:00 MO	A1



Mrs. Vicki A. Forney
 Project Coordinator

ALS Environmental Laboratory Locations Across North America

Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay
 Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

ANALYTICAL RESULTS

Workorder: 2254151 Clinton Twp BOE-CTM (1211-01)

Lab ID: **2254151006** Date Collected: Matrix: Drinking Water
 Sample ID: **CTM-1-163A-EC3-P** Date Received: 8/14/2017 18:45

Parameters	Results	Flag	Units	RDL	Method	Prepared By	Analyzed By	Cntr
METALS								
Lead, Total	15.7		ug/L	2.0	EPA 200.8	8/17/17 17:47 MO	8/17/17 22:08 MO	A1

Vicki Forney
 Mrs. Vicki A. Forney
 Project Coordinator

ALS Environmental Laboratory Locations Across North America


Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay
 Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

ANALYTICAL RESULTS

Workorder: 2254151 Clinton Twp BOE-CTM (1211-01)

Lab ID: **2254151007** Date Collected: Matrix: Drinking Water
 Sample ID: **CTM-1-163A-EC3-F** Date Received: 8/14/2017 18:45

Parameters	Results	Flag	Units	RDL	Method	Prepared	By	Analyzed	By	Cntr
METALS										
Lead, Total	ND		ug/L	2.0	EPA 200.8	8/17/17 17:47	MO	8/17/17 22:11	MO	A1



Mrs. Vicki A. Forney
 Project Coordinator

ALS Environmental Laboratory Locations Across North America


Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay
 Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

ANALYTICAL RESULTS

Workorder: 2254151 Clinton Twp BOE-CTM (1211-01)

Lab ID: **2254151008** Date Collected: Matrix: Drinking Water
 Sample ID: **CTM-1-163A-EC6-P** Date Received: 8/14/2017 18:45

Parameters	Results	Flag	Units	RDL	Method	Prepared	By	Analyzed	By	Cntr
METALS										
Lead, Total	3.0		ug/L	2.0	EPA 200.8	8/17/17 17:47	MO	8/17/17 22:14	MO	A1



Mrs. Vicki A. Forney
 Project Coordinator

ALS Environmental Laboratory Locations Across North America

Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay
 Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

ANALYTICAL RESULTS

Workorder: 2254151 Clinton Twp BOE-CTM (1211-01)

Lab ID: **2254151009** Date Collected: Matrix: Drinking Water
 Sample ID: **CTM-1-163A-EC6-F** Date Received: 8/14/2017 18:45

Parameters	Results	Flag	Units	RDL	Method	Prepared	By	Analyzed	By	Cntr
METALS										
Lead, Total	ND		ug/L	2.0	EPA 200.8	8/17/17 17:47	MO	8/17/17 22:16	MO	A1

Vicki Forney
 Mrs. Vicki A. Forney
 Project Coordinator

ALS Environmental Laboratory Locations Across North America


Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay
 Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

ANALYTICAL RESULTS

Workorder: 2254151 Clinton Twp BOE-CTM (1211-01)

Lab ID: **2254151010** Date Collected: Matrix: Drinking Water
 Sample ID: **CTM-1-163A-EC7-P** Date Received: 8/14/2017 18:45

Parameters	Results	Flag	Units	RDL	Method	Prepared	By	Analyzed	By	Cntr
METALS										
Lead, Total	3.7		ug/L	2.0	EPA 200.8	8/17/17 17:47	MO	8/17/17 22:19	MO	A1



Mrs. Vicki A. Forney
 Project Coordinator

ALS Environmental Laboratory Locations Across North America

Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay
 Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

ANALYTICAL RESULTS

Workorder: 2254151 Clinton Twp BOE-CTM (1211-01)

Lab ID: **2254151011** Date Collected: Matrix: Drinking Water
 Sample ID: **CTM-1-163A-EC7-F** Date Received: 8/14/2017 18:45

Parameters	Results	Flag	Units	RDL	Method	Prepared	By	Analyzed	By	Cntr
METALS										
Lead, Total	ND		ug/L	2.0	EPA 200.8	8/17/17 17:47	MO	8/17/17 22:22	MO	A1



Mrs. Vicki A. Forney
 Project Coordinator

ALS Environmental Laboratory Locations Across North America

Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay
 Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey




34 Dogwood Lane
Middletown, PA 17057
P. 717-944-5541
F. 717-944-1430

CHAIN OF CUSTODY/ REQUEST FOR ANALYSIS

ALL SHADED AREAS MUST BE COMPLETED BY THE CLIENT /
SAMPLER. INSTRUCTIONS ON THE BACK.

COC #:
ALS Qu



* 2 2 5 4 1 5 1 *

Client Name: PARS Environmental Address: 500 Horizon Drive, Suite 540 Contact: Rafael Torres Phone#: 609-890-7277 Project Name/ #: Clinton Twp BOE - CTM (1211-01) Bill To: Rafael Torres, PARS Environmental TAT <input checked="" type="checkbox"/> Normal-Standard TAT is 10-12 business days. <input type="checkbox"/> Rush-Subject to ALS approval and surcharges. Date Required: _____ Approved By: RT Email? <input checked="" type="checkbox"/> -Y aalbertson@parsenviro.com Fax? <input type="checkbox"/> -Y No: _____		Container Type: BP Container Size: 250mL Preservative: HNO3 ANALYSES/METHOD REQUESTED EPA 200.9 (Lead)		Receipt # _____ Cooler Temp: 22 Therm ID: 209 No. of Coolers: Y N Initial: <i>RT</i> Custody Seals Present? _____ (If present) Seals Intact? _____ Received on Ice? _____ COC Labels Complete/Accurate? _____ Cont. in Good Cond.? _____ Correct Containers? _____ Correct Sample Volumes? _____ Correct Preservation? _____ Headspace/Volatiles? _____ Courier Tracking #: _____ Sample/COC Comments	
Sample Description/Location (as it will appear on the lab report) See Attached COC		Enter Number of Containers Per Sample or Field Results Below.		ALS Field Services: <input checked="" type="checkbox"/> Pickup Labor <input type="checkbox"/> Composite Sampling <input type="checkbox"/> Rental Equipment Other: _____	
Project Comments:		LOGGED BY (signature): _____ REVIEWED BY (signature): _____		State Samples Collected In USACE <input type="checkbox"/> Navy <input type="checkbox"/> NY <input type="checkbox"/> <input checked="" type="checkbox"/> CLP-like <input type="checkbox"/> USACE <input type="checkbox"/> NJ <input type="checkbox"/> <input type="checkbox"/> Standard <input type="checkbox"/> Reportable to PADEP? _____ Data Deliverables Yes <input type="checkbox"/> PWSID # _____ EDDS: Format Type _____	
Relinquished By / Company Name <i>[Signature]</i>		Date 8/11/17 8/14 8/14		Received By / Company Name <i>[Signature]</i> <i>[Signature]</i> <i>[Signature]</i>	
1 3 5 9		2 4 6 8 10		Date 8/11/17 8/14 8/14 8/14	




CLINTON TWP
MIDDLE SCHOOL

8/11/17

Facility Name

Facility Address:

Sample #	Sample ID	Sample Time	Comments
FB	CTM-FIELD BLANK	0747	
1	CTM-1-KIT-FP2-P	0748	
2	CTM-1-KIT-FP2-F	0749	
3	CTM-1-KIT-FP4-P	0750	
4	CTM-1-KIT-FP4-F	0751	
5	CTM-1-163A-EC3-P	0752	
6	CTM-1-163A-EC3-F	0753	
7	CTM-1-163A-EC6-P	0754	
8	CTM-1-163A-EC6-F	0755	
9	CTM-1-163A-EC7-P	0756	
10	CTM-1-163A-EC7-F	0757	

Signature of Sampler: 
Sample ID Guide: Bldg ID - Flr - Rm - Type (- Faucet #)