

August 21, 2017

Mr. Rafael Torres  
PARS Environmental  
500 Horizon Drive  
Trenton, NJ 08691

## Certificate of Analysis

Project Name:	<b>School Drinking Water Lead Testing</b>	Workorder:	<b>2254718</b>
Purchase Order:		Workorder ID:	<b>RVS-Round Valley School</b>

Dear Mr. Torres:

Enclosed are the analytical results for samples received by the laboratory on Wednesday, August 16, 2017.

The ALS Environmental laboratory in Middletown, Pennsylvania is a National Environmental Laboratory Accreditation Program (NELAP) accredited laboratory and as such, certifies that all applicable test results meet the requirements of NELAP.

If you have any questions regarding this certificate of analysis, please contact Mrs. Vicki A. Forney (Project Coordinator) at (717) 944-5541.

Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state requirements. The test results meet requirements of the current NELAP standards or state requirements, where applicable. For a specific list of accredited analytes, refer to the certifications section of the ALS website at [www.alsglobal.com/en/Our-Services/Life-Sciences/Environmental/Downloads](http://www.alsglobal.com/en/Our-Services/Life-Sciences/Environmental/Downloads).

This laboratory report may not be reproduced, except in full, without the written approval of ALS Environmental.

ALS Spring City: 10 Riverside Drive, Spring City, PA 19475 610-948-4903

*This page is included as part of the Analytical Report and must be retained as a permanent record thereof.*



Mrs. Vicki A. Forney  
Project Coordinator

### ALS Environmental Laboratory Locations Across North America

Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay  
Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

### SAMPLE SUMMARY

Workorder: 2254718 RVS-Round Valley School

Lab ID	Sample ID	Matrix	Date Collected	Date Received	Collected By
2254718001	RVS-FIELD BLANK	Drinking Water	8/11/2017 07:05	8/16/2017 19:30	Collected by Client
2254718002	RVS-1-KIT-FP2-P	Drinking Water	8/11/2017 07:06	8/16/2017 19:30	Collected by Client
2254718003	RVS-1-KIT-FP2-F	Drinking Water	8/11/2017 07:07	8/16/2017 19:30	Collected by Client
2254718004	RVS-1-KIT-FP3-P	Drinking Water	8/11/2017 07:08	8/16/2017 19:30	Collected by Client
2254718005	RVS-1-KIT-FP3-F	Drinking Water	8/11/2017 07:09	8/16/2017 19:30	Collected by Client

---

### ALS Environmental Laboratory Locations Across North America

**Canada:** Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay  
Vancouver Waterloo · Winnipeg · Yellowknife **United States:** Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York **Mexico:** Monterrey

**SAMPLE SUMMARY**

Workorder: 2254718 RVS-Round Valley School

**Notes**

- Samples collected by ALS personnel are done so in accordance with the procedures set forth in the ALS Field Sampling Plan (20 - Field Services Sampling Plan).
- All Waste Water analyses comply with methodology requirements of 40 CFR Part 136.
- All Drinking Water analyses comply with methodology requirements of 40 CFR Part 141.
- Unless otherwise noted, all quantitative results for soils are reported on a dry weight basis.
- The Chain of Custody document is included as part of this report.
- All Library Search analytes should be regarded as tentative identifications based on the presumptive evidence of the mass spectra. Concentrations reported are estimated values.
- Parameters identified as "analyze immediately" require analysis within 15 minutes of collection. Any "analyze immediately" parameters not listed under the header "Field Parameters" are performed in the laboratory and are therefore analyzed out of hold time.
- Method references listed on this report beginning with the prefix "S" followed by a method number (such as S2310B-97) refer to methods from "Standard Methods for the Examination of Water and Wastewater".
- For microbiological analyses, the "Prepared" value is the date/time into the incubator and the "Analyzed" value is the date/time out the incubator.

**Standard Acronyms/Flags**

J	Indicates an estimated value between the Method Detection Limit (MDL) and the Practical Quantitation Limit (PQL) for the analyte
U	Indicates that the analyte was Not Detected (ND)
N	Indicates presumptive evidence of the presence of a compound
MDL	Method Detection Limit
PQL	Practical Quantitation Limit
RDL	Reporting Detection Limit
ND	Not Detected - indicates that the analyte was Not Detected at the RDL
Cntr	Analysis was performed using this container
RegLmt	Regulatory Limit
LCS	Laboratory Control Sample
MS	Matrix Spike
MSD	Matrix Spike Duplicate
DUP	Sample Duplicate
%Rec	Percent Recovery
RPD	Relative Percent Difference
LOD	DoD Limit of Detection
LOQ	DoD Limit of Quantitation
DL	DoD Detection Limit
I	Indicates reported value is greater than or equal to the Method Detection Limit (MDL) but less than the Report Detection Limit (RDL)
(S)	Surrogate Compound
NC	Not Calculated
*	Result outside of QC limits

**ALS Environmental Laboratory Locations Across North America**

Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay  
Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

### ANALYTICAL RESULTS

Workorder: 2254718 RVS-Round Valley School

Lab ID: **2254718001** Date Collected: 8/11/2017 07:05 Matrix: Drinking Water  
 Sample ID: **RVS-FIELD BLANK** Date Received: 8/16/2017 19:30

Parameters	Results	Flag	Units	RDL	Method	Prepared By	Analyzed By	Cntr
<b>METALS</b>								
Lead, Total	ND		ug/L	2.0	EPA 200.8	8/18/17 15:15 MO	8/18/17 22:02 MO	A1



Mrs. Vicki A. Forney  
 Project Coordinator

#### ALS Environmental Laboratory Locations Across North America


Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay  
 Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

### ANALYTICAL RESULTS

Workorder: 2254718 RVS-Round Valley School

Lab ID: **2254718002** Date Collected: 8/11/2017 07:06 Matrix: Drinking Water  
 Sample ID: **RVS-1-KIT-FP2-P** Date Received: 8/16/2017 19:30

Parameters	Results	Flag	Units	RDL	Method	Prepared By	Analyzed By	Cntr
<b>METALS</b>								
Lead, Total	6.1		ug/L	2.0	EPA 200.8	8/18/17 15:15 MO	8/18/17 22:05 MO	A1



Mrs. Vicki A. Forney  
 Project Coordinator

### ALS Environmental Laboratory Locations Across North America

Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay  
 Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

**ANALYTICAL RESULTS**

Workorder: 2254718 RVS-Round Valley School

Lab ID: **2254718003** Date Collected: 8/11/2017 07:07 Matrix: Drinking Water  
 Sample ID: **RVS-1-KIT-FP2-F** Date Received: 8/16/2017 19:30

Parameters	Results	Flag	Units	RDL	Method	Prepared By	Analyzed By	Cntr
<b>METALS</b>								
Lead, Total	ND		ug/L	2.0	EPA 200.8	8/18/17 15:15 MO	8/18/17 22:07 MO	A1

*Vicki Forney*  
 Mrs. Vicki A. Forney  
 Project Coordinator

**ALS Environmental Laboratory Locations Across North America**


Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay  
 Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

### ANALYTICAL RESULTS

Workorder: 2254718 RVS-Round Valley School

Lab ID: **2254718004** Date Collected: 8/11/2017 07:08 Matrix: Drinking Water  
 Sample ID: **RVS-1-KIT-FP3-P** Date Received: 8/16/2017 19:30

Parameters	Results	Flag	Units	RDL	Method	Prepared By	Analyzed By	Cntr
<b>METALS</b>								
Lead, Total	8.2		ug/L	2.0	EPA 200.8	8/18/17 15:15 MO	8/18/17 22:10 MO	A1



Mrs. Vicki A. Forney  
 Project Coordinator

#### ALS Environmental Laboratory Locations Across North America


Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay  
 Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

### ANALYTICAL RESULTS

Workorder: 2254718 RVS-Round Valley School

Lab ID: **2254718005** Date Collected: 8/11/2017 07:09 Matrix: Drinking Water  
 Sample ID: **RVS-1-KIT-FP3-F** Date Received: 8/16/2017 19:30

Parameters	Results	Flag	Units	RDL	Method	Prepared By	Analyzed By	Cntr
<b>METALS</b>								
Lead, Total	2.9		ug/L	2.0	EPA 200.8	8/18/17 15:15 MO	8/18/17 22:18 MO	A1



Mrs. Vicki A. Forney  
 Project Coordinator

### ALS Environmental Laboratory Locations Across North America

Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay  
 Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey





