



*Effective and Economical
Environmental Solutions*

**Lead-in-Drinking Water Sampling
Round Valley Elementary School
128 Cokesbury Road
Lebanon, NJ 08833**

Karl Environmental Group Project #: 21-0738

August 19, 2021

Prepared for:

Mr. Frank Bolognini
Buildings & Grounds Supervisor
Clinton Township School District
128 Cokesbury Road
Lebanon, NJ 08833

Prepared by:

Karl Environmental Group
20 Lauck Road
Mohnton, PA 19540
Tel: (800) 527-5581
Fax: (610) 856-5040



20 Lauck Road
Mohnton, PA 19540
Tel: (800) 527-5581
Fax: (610) 856-5040
Web: www.karlenv.com

August 19, 2021

Mr. Frank Bolognini
Buildings & Grounds Supervisor
Clinton Township School District
128 Cokesbury Road
Lebanon, NJ 08833

**Re: Lead-in-Drinking Water Sampling
Clinton Township School District
Round Valley Elementary School
Karl Environmental Group Project #: 21-0738**

Dear Mr. Bolognini:

Thank you for selecting Karl Environmental Group ("Karl") for this project. This report details the methods and findings of the lead in drinking water services as per New Jersey state regulations (amendments to N.J.A.C 6A:26 Educational Facilities) performed at the Round Valley Elementary School (the "Facility"), on August 3, 2021.

1.0 PROJECT BACKGROUND

Karl Environmental was contacted by Mr. Frank Bolognini of the Clinton Township School District (the "Client") to conduct lead in drinking water sampling to determine the lead content of drinking water from sources throughout the Facility. The purpose of lead in drinking water sampling is to determine if any sampled drinking water sources exhibit lead levels exceeding the Regulatory Action Level of 15 parts per billion (ppb).

Drinking water collection points included any water sources from which a student, staff, or faculty may reasonably drink; or from which the water may be used for cooking or beverage preparation, including kitchen faucets and sinks in Faculty/Staff lounges.



2.0 LEAD IN DRINKING WATER

Lead is a toxic substance that can be harmful to human health. As compared to adults, children are more susceptible to the detrimental health effects of lead, as their nervous systems are not yet fully developed. Exposure to lead can occur in a variety of ways including through food, soil, deteriorating lead-based paint, and drinking water. Lead can leach into drinking water from plumbing materials such as pipes and solder, as well as brass plumbing fixtures. For this investigation, planning, preparation, methodology, sampling, and follow-up actions were conducted according to the technical guidance provided by New Jersey following the adoption of amendments to N.J.A.C. 6A:26: Educational Facilities, requiring the sampling of drinking water for lead in schools.

3.0 DRINKING WATER SAMPLING METHODOLOGY

Karl Environmental collected drinking water samples from water outlets throughout the Round Valley Elementary School facility. At each collection point, Karl Environmental filled a 250 milliliter (mL) wide-mouth high density polyethylene (HDPE) sample collection bottle from the selected water source. Samples were collected after the water in each building had not been used for at least 8 hours, but not more than 48 hours. Samples were preserved using concentrated Nitric Acid (HNO_3). The initial sample at each collection point represents the first draw sample. The first draw sample is representative of the water from the end point of the water source (i.e., the bubbler or tap).

A field blank using lead-free laboratory reagent water was also collected at each Facility during the sampling event to rule out contamination of samples during the collection and transportation process. All samples were recorded under proper chain of custody and couriered to Suburban Testing Labs (Suburban), a New Jersey certified laboratory (NJ Lab ID #PA081) located in Reading, Pennsylvania for analysis by EPA method 200.8, NJ DOE. During the sampling event on August 3, 2021, Karl Environmental collected the following number of samples at the facility:

Round Valley School

- Twenty-Two First Draw Samples
- One Field Blank



4.0 DRINKING WATER ANALYSIS RESULTS

The analytical lead in drinking water results for each sample collected are listed below:

Table 1: Round Valley Elementary School – August 3, 2021

Sample I.D.	Type of Collection Point	Lead Concentration (ppb)	Above Regulatory Action Level?
RVS-BLANK	Field Blank	<1.00	No
RVS-01-H Boiler-WC1-P	Water Fountain	<1.00	No
RVS-01-H Boiler-B1-P	Bottle Filler	<1.00	No
RVS-01-H Boiler-WC2-P	Water Fountain	<1.00	No
RVS-01-H Boiler-B2-P	Bottle Filler	<1.00	No
RVS-01-NURSE-NS1-P	Sink	9.07	No
RVS-01-NURSE-NS2-P	Sink	<1.00	No
RVS-01-MO CONF-TF-P	Sink	6.36	No
RVS-01-MO COPY-TF-P	Sink	3.73	No
RVS-01-KIT-FP1-P	Sink	7.03	No
RVS-01-KIT-FP2-P	Sink	12.1	No
RVS-01-KIT-FP3-P	Sink	10.2	No
RVS-01-CAFE-WC-P	Water Fountain	5.26	No
RVS-01-RM 16-TF-P	Sink	8.77	No
RVS-01-RM 8-WC1-P	Water Fountain	<1.00	No
RVS-01-H COPY-WC-P	Water Fountain	<1.00	No
RVS-01-H COPY-B-P	Bottle Filler	<1.00	No
RVS-01-5 TH GR HALL-WC-P	Water Fountain	<1.00	No
RVS-01-5 TH GR HALL-B-P	Bottle Filler	<1.00	No
RVS-01-LIB-TF-P	Sink	12.7	No
RVS-01-BOE KIT-TF-P	Sink	2.92	No
RVS-01-KIT-FP-P	Sink	17.1	Yes
RVS-01-H RM8-BF-P	Bottle Filler	<1.00	No

Laboratory analytical results were compared to the Regulatory Action Level of 15 ppb for lead. Analysis of lead in the first draw drinking water samples indicated that at the time of the sampling one (1) outlet at the Round Valley Elementary School exceeded the Action Level. Upon receipt of results the District was notified and removed the outlets from service.



5.0 CONCLUSIONS & RECOMMENDATIONS

Karl Environmental Group collected first draw samples from drinking water sources throughout the Round Valley Elementary School of the Clinton Township Board of Education. First draw sample results indicated that of the Twenty-Two samples collected, one of the samples exhibited lead levels above the Regulatory Action Level of 15 ppb. At the conclusion of the lead in drinking water services, Karl Environmental offers the following recommendations at this time:

- The District should perform second draw flush sampling of all outlets exceeding the regulatory action level of 15ppb prior to placing outlets above the action level back in service.
- Continue to monitor lead in drinking water levels as part of a regular sampling and maintenance plan, as per New Jersey State regulations. Amendments will require district-wide sampling every three (3) years.
- In the interim, when drinking water outlets are replaced/added, or the plumbing is disturbed, sampling of the impacted outlets should be completed to determine if lead levels were affected.
- Implement an aerator cleaning maintenance program to prevent the build-up of debris behind the screen which may contribute to elevated lead levels.
- Enter all filter maintenance, aerator maintenance, plumbing repairs/changes and any other pertinent information into the Field Log Book for each Facility.
- Use only cold water for food and beverage preparation. Hot water is more likely to contribute to the corrosion of plumbing materials and therefore contain a greater level of contaminants from the plumbing system.



6.0 LIMITATIONS

This investigation focused on lead in drinking water only. No other heavy metals or additional contaminants were sampled for or analyzed. Lead concentrations can change as water continues to move through the water system. Each sample was a grab sample and represents lead concentrations only at the specific time of collection and may vary based on the water usage in the facility. Interpretation of these results is only valid if the facility is serviced by a municipal water supplier or water utility.

This lead sampling event was in response to the amendments to N.J.A.C. 6A:26, Educational Facilities dated July 13, 2016, which requires testing for lead in the drinking water of public and charter school districts every three (3) years.

7.0 CLOSING

Thank you for using Karl to assist you with this project. Please do not hesitate to call if you have any questions relating to this report or for any other environmental health and safety concerns.

Respectfully submitted,
Karl Environmental Group

Aja Slater

Aja Slater
Industrial Hygienist
aslater@karlenv.com
610-856-7700 (Office)
610-856-5040 (Fax)

Attachments:
A – Laboratory Analytical Report



Attachment A
Laboratory Analytical Results



Results Report

Order ID: 1H01930

Karl Environmental Group
20 Lauck Road
Mohnton, PA 19540

Project: Clinton Township School District

Attn: Jake Edwards

Regulatory ID:

Sample Number: 1H01930-01
Collector: JE

Site: RVS-Blank
Collect Date: 08/03/2021 6:11 am

Sample ID:
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 08/04/21 AER 08/12/21 17:41 RJS

Sample Number: 1H01930-02
Collector: JE

Site: RVS-01-H BOILER-WC1-P
Collect Date: 08/03/2021 6:11 am

Sample ID:
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 08/04/21 AER 08/12/21 18:50 RJS

Sample Number: 1H01930-03
Collector: JE

Site: RVS-01-H BOILER-B1-P
Collect Date: 08/03/2021 6:11 am

Sample ID:
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 08/04/21 AER 08/12/21 18:53 RJS

Sample Number: 1H01930-04
Collector: JE

Site: RVS-01-H BOILER-WC2-P
Collect Date: 08/03/2021 6:11 am

Sample ID:
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 08/04/21 AER 08/12/21 17:30 RJS

Sample Number: 1H01930-05
Collector: JE

Site: RVS-01-H-BOILER-B2-P
Collect Date: 08/03/2021 6:11 am

Sample ID:
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 08/04/21 AER 08/12/21 17:56 RJS

Report Generated On: 08/16/2021 12:41 pm 1H01930
STL_Results Revision #1.9 Effective: 04/16/2020





SUBURBAN TESTING LABS

Sample Number: 1H01930-06	Site: RVS-01-NURSE-NS1-P	Sample ID:
Collector: JE	Collect Date: 08/03/2021 6:16 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	9.07	µg/L	EPA 200.8	1.00	1	08/04/21	AER	08/12/21 17:58	RJS
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1H01930-07	Site: RVS-01-NURSE-NS2-P	Sample ID:
Collector: JE	Collect Date: 08/03/2021 6:16 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	08/04/21	AER	08/12/21 18:00	RJS
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1H01930-08	Site: RVS-01-MO CONF-TF-P	Sample ID:
Collector: JE	Collect Date: 08/03/2021 6:17 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	6.36	µg/L	EPA 200.8	1.00	1	08/04/21	AER	08/12/21 18:02	RJS
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1H01930-09	Site: RVS-01-MO COPY-TF-P	Sample ID:
Collector: JE	Collect Date: 08/03/2021 6:19 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	3.73	µg/L	EPA 200.8	1.00	1	08/04/21	AER	08/12/21 18:13	RJS
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1H01930-10	Site: RVS-01-KIT-FP1-P	Sample ID:
Collector: JE	Collect Date: 08/03/2021 6:22 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	7.03	µg/L	EPA 200.8	1.00	1	08/04/21	AER	08/12/21 18:15	RJS
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1H01930-11	Site: RVS-01-KIT-FP2-P	Sample ID:
Collector: JE	Collect Date: 08/03/2021 6:22 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	12.1	µg/L	EPA 200.8	1.00	1	08/04/21	AER	08/12/21 18:17	RJS
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1H01930-12	Site: RVS-01-KIT-FP3-P	Sample ID:
Collector: JE	Collect Date: 08/03/2021 6:22 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	10.2	µg/L	EPA 200.8	1.00	1	08/04/21	AER	08/12/21 18:19	RJS
------	------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 08/16/2021 12:41 pm 1H01930
 STL_Results Revision #1.9 Effective: 04/16/2020





SUBURBAN TESTING LABS

Sample Number: 1H01930-13	Site: RVS-01-CAFE-WC-P	Sample ID:
Collector: JE	Collect Date: 08/03/2021 6:25 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	5.26	µg/L	EPA 200.8	1.00	1	08/04/21	AER	08/12/21 18:59	RJS
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1H01930-14	Site: RVS-01-RM 16-TF-P	Sample ID:
Collector: JE	Collect Date: 08/03/2021 6:32 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	8.77	µg/L	EPA 200.8	1.00	1	08/04/21	AER	08/12/21 19:01	RJS
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1H01930-15	Site: RVS-01-H RM 8-WC1-P	Sample ID:
Collector: JE	Collect Date: 08/03/2021 6:33 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	08/04/21	AER	08/12/21 18:25	RJS
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1H01930-16	Site: RVS-01-H COPY-WC-P	Sample ID:
Collector: JE	Collect Date: 08/03/2021 6:41 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	08/04/21	AER	08/12/21 18:27	RJS
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1H01930-17	Site: RVS-01-H COPY-B-P	Sample ID:
Collector: JE	Collect Date: 08/03/2021 6:41 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	08/04/21	AER	08/12/21 18:38	RJS
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1H01930-18	Site: RVS-01-5TH GR HALL-WC-P	Sample ID:
Collector: JE	Collect Date: 08/03/2021 6:45 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	08/04/21	AER	08/12/21 18:40	RJS
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1H01930-19	Site: RVS-01-5TH GR HALL-B-P	Sample ID:
Collector: JE	Collect Date: 08/03/2021 6:45 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	08/04/21	AER	08/12/21 18:42	RJS
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 08/16/2021 12:41 pm 1H01930
 STL_Results Revision #1.9 Effective: 04/16/2020





Sample Number: 1H01930-20	Site: RVS-01-LIB-TF-P	Sample ID:
Collector: JE	Collect Date: 08/03/2021 6:47 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	12.7	µg/L	EPA 200.8	1.00	1	08/04/21	AER	08/12/21 18:44	RJS
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1H01930-21	Site: RVS-01-BOE KIT-TF-P	Sample ID:
Collector: JE	Collect Date: 08/03/2021 6:51 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	2.92	µg/L	EPA 200.8	1.00	1	08/04/21	AER	08/12/21 18:46	RJS
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1H01930-22	Site: RVS-01-KIT-FP-P	Sample ID: KIT-FP4-P
Collector: JE	Collect Date: 08/03/2021 6:22 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	17.1	µg/L	EPA 200.8	1.00	1	08/04/21	AER	08/12/21 18:48	RJS
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1H01930-23	Site: RVS-01-H RM8-BF-P	Sample ID:
Collector: JE	Collect Date: 08/03/2021 6:33 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	08/04/21	AER	08/12/21 17:35	RJS
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Report Generated On: 08/16/2021 12:41 pm 1H01930
 STL_Results Revision #1.9 Effective: 04/16/2020





SUBURBAN
TESTING LABS

Reviewed and Released By:

Ryan F Knerr
Project Manager II

Report Generated On: 08/16/2021 12:41 pm 1H01930
STL_Results Revision #1.9 Effective: 04/16/2020





61



1H01930
Ryan F Knerr

TAT(Check One): Standard 24hr 48hr 72hr Other
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: Karl Environmental Group

Address: 20 Lauck Road
Mohnton PA 19540

Phone: 610-856-07700

Email: aslater@karlenv.com

Contact Name: Aja Slater/ Jake Edwards

P.O. Info: _____

Clinton Township School District 21-0738

Address: Round Valley Elementary

128 Cokesbury Road, Lebanon NJ 08833

Regulatory ID (SDWA/Permit #): _____

Comments:


NJ DOE Lead in Drinking Water - Page 1

NR 8/3/21

STL Sample Number	Sample Description / Site ID: <i>10: S/F0339</i>	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:	
							Matrix	Sample Type	Bottle Type	Preservative		
<i>(8) 250 ml P HNO₃ Preserved w/ 20 drops HNO₃ pH < 2</i>												
<i>★</i> RVS- Blank		8/3/2021	6:11	JE	Lead, 200.8, NJ DOE	1	PW	G	P	H		Field Blank
RVS-01-H BOILER-WC1-P		8/3/2021	6:11	JE	Lead, 200.8, NJ DOE	1	PW	G	P	H		
RVS-01-H BOILER-B1-P		8/3/2021	6:11	JE	Lead, 200.8, NJ DOE	1	PW	G	P	H		
RVS-01-H BOILER-WC2-P		8/3/2021	6:11	JE	Lead, 200.8, NJ DOE	1	PW	G	P	H		
RVS-01-H BOILER-B2-P		8/3/2021	6:11	JE	Lead, 200.8, NJ DOE	1	PW	G	P	H		
RVS-01-NURSE-NS1-P		8/3/2021	6:16	JE	Lead, 200.8, NJ DOE	1	PW	G	P	H		
RVS-01-NURSE-NS2-P		8/3/2021	6:16	JE	Lead, 200.8, NJ DOE	1	PW	G	P	H		
RVS-01-MO CONF-TF-P		8/3/2021	6:17	JE	Lead, 200.8, NJ DOE	1	PW	G	P	H		

Relinquished By: <i>[Signature]</i>	Count: <i>8</i>	Date: <i>8/3/21</i>	Temp °C: _____	Sample Conditions Submitted with COC? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N Number of containers match number on COC? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N All containers in tact? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N Tests within holding times? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N 40 mL VOA vials free of headspace? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	Matrix Key NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample	Bottle Type Key P = Plastic G = Glass GA = Glass Amber VOA = 40mL G or GA O = Other PP = Sterile Polypropylene PS = Sterile Polystyrene HDPE = High Density Polyethylene
Received By:	Date: _____	Temp °C: _____	Acceptable: Y / N			
Relinquished By:	Date: _____	Temp °C: _____	Acceptable: Y / N	Sample Type Key G = Grab C = Composite 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite	SDWA Sample Types D=Distribution E=Entry Point R=Raw C=Check S=Special M=Maximum Residence	Preservative Key A = Ascorbic Acid H = HCl H = HNO ₃ N = Sodium Thiosulfate OH = NaOH S = H ₂ SO ₄ O = Other NA = None Required
Received in Lab By: <i>[Signature]</i>	Date: <i>8/3/21</i>	Temp °C: <i>15.8</i>	Acceptable: <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N			

Signing this form indicates your agreement with STL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.5 Effective April 24, 2020. Shaded areas are for STL use only.



1H01930
Ryan F Knerr

TAT(Check One): Standard 24hr 48hr 72hr Other
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: Karl Environmental Group

Address: 20 Lauck Road
Mohnton PA 19540

Phone: 610-856-07700

Email: aslater@karlennv.com

Contact Name: Aja Slater/ Jake Edwards

P.O. Info: _____

Project Name: Clinton Township School District 21-0738

Address: Round Valley Elementary
128 Cokesbury Road, Lebanon NJ 08833

Regulatory ID (SDWA/Permit #): _____

Comments:

NJ DOE Lead in Drinking Water - Page 2

NR 8/3/21

STL Sample Number	Sample Description / Site ID	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:	
							Matrix	Sample Type	Bottle Type	Preservative		
<i>A-(3) 250 mL P HNO3</i> <i>Preserved w/ 20 drops HNO3</i> <i>pH = 2</i> Sample Description / Site ID: <i>10:51F0339</i>												
<input checked="" type="checkbox"/>	RVS-01-MO COPY-TF-P	8/3/2021	6:19	JE	Lead, 200.8, NJ DOE	1	PW	G	P	H		
<input checked="" type="checkbox"/>	RVS-01-KIT-FP1-P	8/3/2021	6:22	JE	Lead, 200.8, NJ DOE	1	PW	G	P	H		
<input checked="" type="checkbox"/>	RVS-01-KIT-FP2-P	8/3/2021	6:22	JE	Lead, 200.8, NJ DOE	1	PW	G	P	H		
<input checked="" type="checkbox"/>	RVS-01-KIT-FP3-P	8/3/2021	6:22	JE	Lead, 200.8, NJ DOE	1	PW	G	P	H		
<input checked="" type="checkbox"/>	RVS-01-CAFÉ-WC-P	8/3/2021	6:25	JE	Lead, 200.8, NJ DOE	1	PW	G	P	H		
<input checked="" type="checkbox"/>	RVS-01-RM 16-TF-P	8/3/2021	6:32	JE	Lead, 200.8, NJ DOE	1	PW	G	P	H		
<input checked="" type="checkbox"/>	RVS-01-H RM 8-WC1-P	8/3/2021	6:33	JE	Lead, 200.8, NJ DOE	1	PW	G	P	H		
<input checked="" type="checkbox"/>	RVS-01-H COPY-WC-P	8/3/2021	6:41	JE	Lead, 200.8, NJ DOE	1	PW	G	P	H		

Relinquished By: <i>[Signature]</i>	Count: <i>8</i>	Date: <i>8/3/21</i>	Temp °C: _____	Sample Conditions Submitted with COC? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N Number of containers match number on COC? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N All containers in tact? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N Tests within holding times? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N 40 mL VOA vials free of headspace? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	Matrix Key NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample	Bottle Type Key P = Plastic G = Glass GA = Glass Amber VOA = 40mL G or GA PP = Sterile Polypropylene PS = Sterile Polystyrene HDPE = High Density Polyethylene O = Other
Received By:	Date: _____	Temp °C: _____	Acceptable: Y / N			
Relinquished By:	Date: _____	Temp °C: _____	Acceptable: Y / N	Sample Type Key G = Grab C = Composite 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite	SDWA Sample Types D=Distribution E=Entry Point R=Raw C=Check S=Special M=Maximum Residence	Preservative Key A = Ascorbic Acid C = HCl H = HNO ₃ N = Sodium Thiosulfate OH = NaOH S = H ₂ SO ₄ O = Other NA = None Required
Received in Lab By: <i>[Signature]</i>	Date: <i>8/3/21</i>	Temp °C: <i>15.8</i>	Acceptable: <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N			

Signing this form indicates your agreement with STL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.5 Effective April 24, 2020. Shaded areas are for STL use only.



1H01930
Ryan F Knerr

TAT (Check One): Standard 24hr 48hr 72hr Other
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: Karl Environmental Group
Address: 20 Lauck Road
Mohnton PA 19540
Phone: 610-856-07700
Email: aslater@karlenv.com
Contact Name: Aja Slater/ Jake Edwards
P.O. Info: _____

Project Name: Clinton Township School District 21-0738
Address: Round Valley Elementary
128 Cokesbury Road, Lebanon NJ 08833
Regulatory ID (SDWA/Permit #): _____

Comments:

NJ DOE Lead in Drinking Water - Page 3

NR 8/3/21

STL Sample Number	Sample Description / Site ID	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested	Bottle Quantity	See Codes Below				Comments / Field Data	
							Matrix	Sample Type	Bottle Type	Preservative		
★ (7)	250 mL P HNO ₃ Preserved w/ 20 drops HNO ₃ pH 2 Sample Description / Site ID: 10: SIF0339											
★	RVS-01-H COPY-B-P	8/3/2021	6:41	JE	Lead, 200.8, NJ DOE	1	PW	G	P	H		
	RVS-01-5TH GR HALL-WC-P	8/3/2021	6:45	JE	Lead, 200.8, NJ DOE	1	PW	G	P	H		
	RVS-01-5TH GR HALL-B-P	8/3/2021	6:45	JE	Lead, 200.8, NJ DOE	1	PW	G	P	H		
	RVS-01-LIB-TF-P	8/3/2021	6:47	JE	Lead, 200.8, NJ DOE	1	PW	G	P	H		
	RVS-01-BOE KIT-TF-P	8/3/2021	6:51	JE	Lead, 200.8, NJ DOE	1	PW	G	P	H		
	RVS-01-KIT-FP-P → see comments	8/3/2021	6:22	JE	Lead, 200.8, NJ DOE	1	PW	G	P	H		KIT-FP-P
↓	RVS-01-H RM8-BF-P	8/3/2021	6:33	JE	Lead, 200.8, NJ DOE	1	PW	G	P	H		

Relinquished By: <i>[Signature]</i>	Count: 7	Date: 8/3/21	Temp °C: _____	Sample Conditions Submitted with COC? <input checked="" type="checkbox"/> Y / N Number of containers match number on COC? <input checked="" type="checkbox"/> Y / N All containers in tact? <input checked="" type="checkbox"/> Y / N Tests within holding times? <input checked="" type="checkbox"/> Y / N 40 mL VOA vials free of headspace? <input checked="" type="checkbox"/> Y / N	Matrix Key NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample	Bottle Type Key P = Plastic G = Glass GA = Glass Amber VOA = 40mL G or GA PP = Sterile Polypropylene PS = Sterile Polystyrene HDPE = High Density Polyethylene O = Other
Received By:		Date:	Temp °C: _____			
Relinquished By:		Date:	Temp °C: _____	Sample Type Key G = Grab C = Composite 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite	SDWA Sample Types D = Distribution E = Entry Point R = Raw C = Check S = Special M = Maximum Residence	Preservative Key A = Ascorbic Acid C = HCl H = HNO ₃ N = Sodium Thiosulfate OH = NaOH S = H ₂ SO ₄ O = Other NA = None Required
Received in Lab By: <i>[Signature]</i>	Count: 7	Date: 8/3/21	Temp °C: 15.8			

Signing this form indicates your agreement with STL's Standard Terms and Conditions unless otherwise specified in writing. SFL059 Rev. 1.5 Effective April 24, 2020. Shaded areas are for STL use only.